



## Lignomat netKCS – model MP32 – Operator Manual

Lignomat Kiln Control System

Overall Kiln Status | Stop | Probes | Overrides | Schedule | History | Samples | Settings | Graphical View

Individual Kiln Status

Change Setup | Pause | Rest

Kiln	Charge	Schedule	Operator	Final MC	Status
1	RO.12.22 RO Winter Ru	5 DM- 6/4 Northern Red Oak	cody	8.0	Running

Fans - Auto

Direction	Speed %	Rem Time
B	50	2:47 / 3:00

Temperature °F

Desired	Active	Inactive
110.0	71.8	74.0
Zone2	71.7	73.8

Internal desired Temp:73.1

EMC %

Desired	Active	Inactive
19.0	9.5	9.5

Internal desired EMC:10.5

MC #	1	2	3	4	5	6	7	8	Manual Avg
%	21.8	21.8	21.8	21.8	21.8	21.8	21.8	21.8	53.7
Species	1	1	1	1	1	1	1	1	
Active	X								

Elapsed Time

Total	0d 00:12
Heating	0d 00:12
Warming	0d 00:00
Drying	0d 00:00
Conditioning	0d 00:00
Cooling	0d 00:00
Heat Treatment	0d 00:00

Regulators - Auto

Heat	Auto	On
Vent	Auto	Off
Spray	Auto	Off
Steam Pressure	0	